



**Town of Amherst**  
 Fire Safety Division  
 5583 Main Street  
 Williamsville, NY 14221

Phone: (716)631-7095  
 Fax: (716)631-7192

## Annual Fire Hydrant Inspection

Address:	DATE:
Property Name:	
Inspector:	PHONE:
Hydrant Location(s):	
Manufacture and Date (On Hydrant):	

\*\*YES = Satisfactory    NO = Unsatisfactory (Explain Below)\*\*

<b>Service Completed:</b>	<b>YES</b>	<b>NO</b>
Hydrant caps slightly more than hand tight.		
There are no leaks in the top of the hydrant.		
There are no leaks in the gasket under caps.		
There are no cracks in the hydrant barrel.		
Hydrant drains properly.		
Operating nut is not worn and does not have rounded corners.		
Outlet threads are not damaged.		
Lubricate operating nut.		
Lubricate packing.		
Lubricate thrust collar.		
Hydrant flushed until clear. (1 minute Minimum)		
Clearly visible, clear access to & around Hydrant (3' Minimum)		
Center Steamer nut height to grade (18" - 36").		
Hydrant is RED in color. (Paint in good condition)		

<b>Flow Test: (Every 5 Years MINIMUM)</b>
Hydrant Capacity:
Turns To Full Open:
Static PSI Test:
Residual PSI Test:

**COMMENTS:**