



**TOWN OF AMHERST**  
**FIRE SAFETY DIVISION**  
 5583 MAIN STREET  
 WILLIAMSVILLE, NY 14221

**Phone:**  
 (716) 631-7095  
**Fax:**  
 (716) 631-7192

**Email:**  
[firesafety@amherst.ny.us](mailto:firesafety@amherst.ny.us)

## PRIVATE HYDRANT INSPECTION

Address:	Date:
Property Name:	
Hydrant Location:	
Manufacture & Date (On Hydrant):	
Inspector / Company:	Phone:

\*\*YES = Satisfactory    NO = Unsatisfactory (Explain in Comments)\*\*

<b>Service Completed:</b>	<b>YES</b>	<b>NO</b>
Hydrant caps slightly more than hand tight.		
There are no leaks in the top of the hydrant.		
There are no leaks in the gasket under caps.		
There are no cracks in the hydrant barrel.		
Hydrant drains properly.		
Operating nut is not worn and does not have rounded corners.		
Outlet threads are not damaged.		
Lubricate operating nut.		
Lubricate packing.		
Lubricate thrust collar.		
Hydrant flushed until clear. (1 minute Minimum)		
Clearly visible, clear access to & around Hydrant (3' Minimum) ("Main Connection" facing towards road/drive)		
Center Steamer nut height to grade (18" - 36").		
Hydrant is RED in color. (Paint in good condition)("Safety Red")		
Hydrant has marker.		

<b>Flow Test: (Every 5 Years MINIMUM)</b>	<b>Last Performed:</b>
Static Pressure: (PSI)	Flow Rate: (GPM)
Residual Pressure: (PSI)	@ 0 PSI: (GPM)
Pitot Pressure: (PSI)	@ 20PSI: (GPM)
Outlet Size Used: (Inches)	Coefficient:

**COMMENTS:**

---



---



---



---