

# CARMINAWOOD DESIGN

November 9, 2022

Jeffrey Burroughs, PE  
Town Engineer  
Town of Amherst  
1100 North Forest Road  
Williamsville, NY 14221

**Re: Multi-Family Project - 2635, 2671, 2691 North Forest Road  
Compliance Letter - Inflow and Infiltration Reduction Program**

Dear Mr. Burroughs:

This compliance letter is being submitted by PB Investors, LLC, project sponsor for the proposed multi-family project at 2635, 2671 and 2691 North Forest Road in Getzville, New York.

The Project Sponsor agrees to comply with the Town of Amherst's I/I mitigation-offset requirements for the wastewater flow from the proposed development.

Wastewater flow from the proposed development was generated as follows:

$$42,680 \text{ gpd} * 4.01 = 171,088 \text{ gpd} / 1440 = 118.81 \text{ gpm} * 4 = 475.24 \text{ gpm}$$

Based on the Town's requirement of \$250 / gpm x 475.24 gpm = \$118,810.98 the Project Sponsor's financial contribution of the Town's "Trust in Agency" fund.

The Project Sponsor also agrees to make this contribution prior to acceptance of the PIP's.

**Agreed and Accepted:**

  
\_\_\_\_\_  
Paul Bliss  
PB Investors, LLC

Date: 11-10-22